

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1050775

**Product:** Voltage discharge gap

**Type:** V 25-B+C/...+NPE, V 20-C/...+NPE

**Rating:** 255 V AC, 50/60 Hz, 40 kA

**Ordering firm:** OBO Bettermann Praha s. r. o.  
Modletice 81, 251 01 Říčany u Prahy, Czech Republic

**Manufacturer:** OBO Bettermann GmbH + Co.KG  
Hütinger Ring 52, Menden D-58694, Germany

**Trade mark:**

**The test results are stated in the test-report No.:** 502669-01/01 of: 28.07.2005

**A sample of the product was found to be in conformity with:**  
ČSN EN 61643-11:03

**The validity of the certificate is limited to:** 31.7.2008

1.8.2005

Prague

Pavel Kudrna  
Certification and Inspection Manager



Stamp



502669-01